

2019

	Hydrants =====>	West Mayfield			2017	
Location	Type (M=Mueller; D=Darling; K=Kennedy)	Pressure	Condition	Repairs	Date	Inspector
Patterson Ave & Harding St	D		WONT OPEN 10 TURNS HOWEVER		APRIL 4	VKLG
Patterson Ave & Brook St	M	80		OK		
Coolidge St & Ross Ave	D	70		OK		
Ross Ave & 18th Ave (12th Ave)?	M					
18th Ave & Cottage St (12th Ave)?	D	60	NO DRAIN FLUSHED			
Rock Ave at STD Steel Specialty Co.	K	60		OK		
3rd Ave & Rock Ave	M	70		OK		
3rd Ave S. of 37th St Jamison St	M	70		OK		
Harbinson Rd & 37th St	M	60		OK		
3rd Ave Pine St N of 37th St	M	60		OK		
2nd Ave & 37th St By Manor	D	60		OK		
4th Ave & 37th St	M	60	WONT DRAIN FLUSHED			
4th Ave & Walnut St	M	60		OK		
4th Ave & 43rd St	M	60		OK		
4th Ave & 47th St	D		VERY LITTLE WATER OPEN ALL THE WAY			
4th Ave & 48th St	D	60		OK		
Mayfield Alley off Harbinson	D	150		OK		
5th Ave & 37th St	M	40		OK		
5th Ave N of 37th St (Front of 3761)	D	40	SLOW DRAIN	OK		
5th Ave & 44th St	D	50		OK		
6th Ave & 36th St (3616 Matilda)	D	120		OK		
6th Ave & 37th St	D	120		OK		
6th Ave & 44th St	M	150		OK		
7th Ave & 45th St	M	120		OK		
7th Ave & 37th St	M	120				

4-5-19

Short St & 36th St	D	120			OK	PKG
8th Ave & 37th St	M	110			OK	
8th Ave & 43rd St	M	110			OK	
8th Ave & 46th St	K	110			OK	
37th St N of Jean St	M	110			OK	
37th St Entrance to Mayfield Village	M	80			OK	
Project Rd and High St	M	70			OK	
High St West of Project Rd	M	60	slow drain		OK	
High St	D	70			OK	
37th St & High St	M	90			OK	
Bowden St W. of Rock Ave	D	100			OK	
Rock Ave S of 37th St Ext	M	110			OK	
Rock Ave W of Harv Inter	M	120			OK	✓